

# Water Softener Engineering Specifications

## Excalibur Water Systems Model EWS S15180 Simplex Water Softener Electronic Metered Initiated Service Operation

Supply one (1), only Excalibur Water Systems Model EWS S15180 Sodium Simplex Water Softener. The system shall be designed to operate under pressure from 40 psig (minimum) to 110 psig (maximum).

### Mineral Tank

Supply one (1), only 18" diameter x 65" high 4" top opening premium quality PE liner with FRP filament winding mineral tank. Maximum operating pressure up to 150 psig with a maximum operating temperature of 120°F. Mineral tank must be NSF/ANSI Standard 44 as well as PED certified.

### Collection & Distribution

Supply one (1), only 1.5" high impact FDA approved hub and lateral high flow distributor that shall be utilized to evenly collect and distribute the flow of water over the entire bed.

### Brine Tank

Supply one (1), only 24" diameter x 50" high density capacity polyethylene combination salt storage/brine storage tank complete with salt grid platform for dry salt storage. The brine tank will be of dry salt design capable of holding 900 lbs of salt.

### Brine Float

Supply One (1), only series 474 brine float to eliminate brine tank overflowing. Safety float / brine valve delivers water demand for high flow brine draws and refill eliminating pre-checking during brine refill when air in the brine line could cause excessive flow rates. The brine float is to be enclosed inside a brine well with cap and secured utilizing a two-piece overflow set.

### Control System

Supply One (1) main operating 1.5" control valve shall be made of epoxy coated lead free brass and all wetted parts shall be non-corrosive. The drain port consists of a 1.25" FNPT receives a quick disconnect 3/4" adapter elbow that can swivel 180 degrees for easy orientation. The brine port has quick connected elbow retained by clip utilizes 1/2" compression nut and swivels 270 degrees for easy orientation. The distributor pilot for the control valve is 1.5" NPS pipe. Control valve utilizes a remote inline electronic flow meter with Hall Effect sensor which must be installed on the outlet port of the control valve. This meter shall be accurate from 0.5 to 75 gallons per minute at +/- 5%. Control valve will have a single main piston, patent 1-piece compressible seal/ spacer stack assembly and have an internal brine regenerant piston. Valve must be a top-mount design with a 15-volt electronic microprocessor controller. Control valve shall have fully adjustable regeneration cycle duration times for backwash, downflow brine/slow rinse, 2<sup>nd</sup> backwash, fast rinse, soft water brine refill, and return to service. Control valves shall be made of non-corrosive materials, including all wetted parts.

### Microprocessor Controller

The solid-state microprocessors shall have a coin cell lithium battery for 8-hour time of day upkeep. Microprocessor will have front panel displays to show current time of day, volume remaining, current flow rate, a system totalizer and days to regeneration if day override is programmed (availability range of 1 day to 28 days). The controller will allow for five methods to initiate regeneration; meter immediate, meter delayed, time clock delayed, or pressure differential delayed or immediate. It shall provide operating history for days since last regeneration, gallons used since last regeneration, total days in service, and total number of regenerations since it was installed which will all be stored in non-volatile memory.

**Turbine & Volumetric Meter**

Supply one (1), only 1.5" Male X Female NPT made of 316 stainless steel meter with magnetic pulse hall effect turbine remote meter accuracy must be +/- 5% with a flow rate range of 0.5 – 75.0 GPM. Other meters will not be accepted. This meter must also be certified to NSF/ANSI 61 and 372.

**Power Supply**

Supply one (1), only North American plug-in type power transformer with electrical specifications output voltage of 15 VDC with the output current not exceeding 500 mA.

**Ion-Exchange Resin**

Each vessel shall be supplied with Aldex C-800 resin bead-form with a minimum 8% cross link gel type sodium form high-capacity polystyrene ion-exchange resin with performance capacity of 30,000 (27,000) [20,000] grains per cubic foot when regenerated with 15lbs (10lbs) [6lbs] of salt per cubic foot. The resin shall be solid, of the proper particle size and contain no plates, shells, agglomerates or other shapes which might interfere with the normal functions of the water softener. Tested & certified WQA according to NSF/ANSI 44, 61, 372 and WQA Gold Seal.

**Performance**

The unit shall provide 180,000 (162,000) [120,000] grains capacity between regenerations based on a regeneration of 15lbs (10lbs) [6lbs] of salt per cubic foot of resin. This setting will utilize 90lbs (60lbs) [36lbs] of salt per regeneration.

**Flow Rate**

Minimum flow rate 3.5gpm (0.22 l/s), Critical flow rate of softened water 14.0gpm (0.88 l/s)  
Service flow rate 21.0gpm (1.32 l/s), 15psi ΔP 37.0gpm (2.33 l/s), 25psi ΔP 52.0gpm (3.28 l/s)

**Drain Flow Rate**

Water shall be discharged during the regeneration process at a flow rate of 9.0 GPM (0.57 l/s) for proper regeneration bed expansion process.

**Start-up**

Successful equipment provider shall follow the manufactures printed instructions to start up the system after plumbing and electrical requirements are completed. This includes raw water testing, programming, individual start-up for each softener column, system operation, and product water testing for each column and training of personnel. Set system for medium salting/capacity levels with fixed reserve and immediate regeneration. If needed, the successful bidder shall contract an approved authorization service agent from the manufacture to assist with these procedures.

**Warranty**

Equipment and /or parts shall be covered by manufacturer's replacement warranty as follows:

- Fiberglass Mineral Tanks – TEN (10) YEARS
- Brine Salt Storage Tank – TEN (10) YEARS
- Cation Exchange Resin – TEN (10) YEARS
- Control Valves & Electronics – FIVE (5) YEARS
- All other components – ONE (1) YEAR